

VOC Content Test Certificate

Thursday, 08th February 2018

Supplier: Rodaux Surface Care Pty Ltd (6-9 Hoyle Avenue, Castle Hill, NSW, 2154).

Sample Description: RS 2000 Water Based Sealer.

Date Tested: 2 February 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	RS 2000 Water Based Sealer
General Adhesives and Sealants: 50 grams per Litre as VOC content per material	31 grams per Litre as VOC content per material
<i>We hereby certify RS 2000 is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180203