

VOC Content Test Certificate

Friday 23rd August 2019

Supplier: Rodaux Surface Care Pty Ltd (6/9 Hoyle Avenue, Castle Hill, NSW, 2154, Australia)

Sample Description: Rodaux Penetrating Sealer

Date Tested: August 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 3690 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.2-13.1.1B Green Star Interiors V1.2-12.1.1B</p>	<p align="center">Rodaux Penetrating Sealer</p>
<p>One and two pack performance coatings for floors: 140 grams per Litre as VOC content per material</p>	<p align="center">68 grams per Litre as VOC content per material</p>
<p align="center"><i>We hereby certify Rodaux Penetrating Sealer is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc
Consultant

V1908029